

System Laboratories UK LTD
Classification Report
Classification of reaction to fire
performance of construction products and
building elements in accordance with BS
EN 13501-1:2018

System Laboratories UK
LTD
Unit 13
Apex Park
Leighton Road
Leighton Buzzard
LU7 3RE
United Kingdom
Approved Body 8514

Report Number 342
Issue B
Prepared for Powdertech (Corby) Ltd.
Date 14/09/2023

Issue	Date	Notes
A	29/08/2023	First issue
B	14/09/2023	Correction to sponsor ID

4. Classification and field of application

4.1. Reference of classification

This classification has been carried out in accordance with BS EN 13501-1:2018.

4.2. Classification

The product Evolution, in relation to reaction to fire behaviour is classified:

Fire behaviour Smoke production Flaming droplets
 A2 - s 1 , d 0

Reaction to fire classification:	A2-s1,d0
---	-----------------

4.3. Field of application

This classification is valid for the following product and mounting and fixing parameters:

Thickness	Paint - 60 - 110µm
	Aluminium ≥ 2mm
Colour	Any with organic content ≤ tested (EGOLF 003-2016)
Composition	No variation allowed
Mass Per Unit Area	± 5% of tested values

5. Limitations

This classification document does not represent type approval or certification of the product.

The laboratory has played no part in sampling of the product.